



Ref. No	Location	Problem
1	The Priors	Tight bend in the stream
2	The Priors	Surface water build up
3	Ton Lane	Water build up/Back flow
4	The Corner	Vague sheet piling protection
5	The lagoon	Vague levels of the field
6	The lagoon	Insufficient drainage
7	Southwell Rd Bridge	Not enough capacity, outfalls without flap valves
8	Old Tannery Drive	Malfunctioning of the balancing pond
9	Meravale Bridge	Not sufficient capacity
10	Lime Tree Garden Bridge	Silt deposit; blocked culvert
11	Blenheim Ave Pumping St.	Malfunctioning of the station
12	Victoria Ave	Malfunctioning of the Pumping Station; Road Drains blocked
13	Along A6097	Blocked drainage ditch
14	Pavilion Court	Malfunctioning of the Road Drains; bank on a field side too high



ENVIRONMENT AGENCY

Midlands Region - Lower Trent Area

Environment Agency,
Trentside Offices
West Bridgford
Nottingham
NG2 5FA
Tel: 0115 9455 722

Title: **LOWDHAM IDENTIFIED ISSUES**

Scale: (at A3 size)	Drawn By:	Date:	No:
NONE	BC	19.10.07	LD001